

## SCHEDULE 3

### WATER RESTRICTION TRIGGER LEVELS

SUPPLY (RAW) WATER	WATER RESTRICTON LEVELS				
LOCATION	WATER CONSERVATION MEASURES	LEVEL 1 (Low)	LEVEL 2 (Medium)	LEVEL 3 (High)	LEVEL 4 (Critical)
<b>CARMILA</b> (Carmila Creek Bores)	Any flow greater than 100mm over V-Notch Weir located 100m upstream of bore locations in Carmila Creek	Flow of 100mm or less over V-Notch Weir located 100m upstream of bore locations in Carmila Creek	No flow over V-Notch Weir located 100m upstream of bore locations in Carmila Creek	No visual water in Carmila Creek at the Bores	Raw Water pumps can no longer pump at 1.5l/s each and have to run off one pump to maintain supply
<b>CLERMONT</b> (Theresa Creek Dam)	1m below spillway height	1m to 1.25m below spillway height	1.25m to 1.5m below spillway height	1.5m to 2m below spillway height	Less than 2m below spillway height
<b>DYSART</b> (Supplier Reliant)	100% allocation	Will depend on Mine raw water allocations			
<b>GLENDEN</b> (Supplier Reliant)	100% allocation	Will depend on Mine raw water allocations			
<b>MIDDLEMOUNT</b> (Supplier Reliant)	100% allocation	Will depend on Mine raw water allocations			
<b>MORANBAH</b> (Supplier Reliant)	100% allocation	Will depend on Mine raw water allocations			
<b>NEBO</b> (Bore 2 used as reference point)	Greater than 1200cm above the bore pump	1175cm to 1200cm above the pump	1150cm to 1175cm above the pump	1125cm to 1150cm above the pump	Less than 1125cm above the pump
<b>ST LAWRENCE</b> (St Lawrence Creek Weir)	St Lawrence Weir overflowing	0.5m below Weir overflow	1.0m below Weir overflow	1.5m below Weir overflow	Less than 2m below Weir overflow
<b>POTABLE (DRINKING WATER) Trigger Levels will be Water Treatment Plant failures, major main breaks or other issues that may affect the supply of potable water to customers as per Isaac Regional Councils Customer Charter. Restrictions will be automatic LEVEL 4.</b>					